



**GEOTECHNICAL
SERVICES**

Civil & Geotechnical Engineers
Testing Laboratory

52/3, Darul Aman Society, Haider Ali Road, Karachi.

Ph : (021) 34532851 - 34535607

E-mail : info@geotechnicalservices.com.pk

Web : www.geotechnicalservices.com.pk

Saif Ahmed Saeed
B.E. (Civil) M.Engg AIT Bangkok

Maria Arshad
B.E. (Civil) M.S. (Geotech), NED

Hasan Ahmed Saeed
B.E. (Civil) M.Sc., (Geotech), UK

CLIENT : AQUAFIN

DATE: Oct 30, 2021.

L.R. No.: 674/21

COMPRESSIVE STRENGTH OF GROUT CUBES (2 x 2 x 2)

S. NO.	MARKING	CASTING DATE	TESTING DATE	A G E (Days)	COMPRESSIVE STRENGTH (N/mm ²)
1.	ASCORET-1/6 (w/c Ratio 0.21)	29.10.21.	30.10.21.	01	15.50
2.	“	“	“	“	17.44
3.	“	“	“	“	13.56

For GEOTECHNICAL SERVICES

**MUHAMMAD AMEEN
LABORATORY MANAGER**

NOTES:

- 1) The laboratory does not take responsibility for the sample delivered after office hours.
- 2) The results pertain to the samples supplied to the laboratory.



GEOTECHNICAL SERVICES

Civil & Geotechnical Engineers
Testing Laboratory

52/3, Darul Aman Society, Haider Ali Road, Karachi.

Ph : (021) 34532851 - 34535607

E-mail : info@geotechnicalservices.com.pk

Web : www.geotechnicalservices.com.pk

Saif Ahmed Saeed
B.E. (Civil) M.Engg. AIT Bangkok

Maria Arshad
B.E. (Civil) M.S. (Geotech), NED

Hasan Ahmed Saeed
B.E. (Civil) M.Sc., (Geotech), UK

CLIENT : AQUAFIN

DATE: Nov 05, 2021.

L.R. No.: 674/21

COMPRESSIVE STRENGTH OF GROUT CUBES (2 x 2 x 2)

S. NO.	MARKING	CASTING DATE	TESTING DATE	AGE (Days)	COMPRESSIVE STRENGTH (N/mm ²)
1.	ASCORET-1/6 (w/c Ratio 0.21)	29.10.21.	05.11.21.	07	31.01
2.	"	"	"	"	32.94
3.	"	"	"	"	31.01

For GEOTECHNICAL SERVICES

**MUHAMMAD AMEEN
LABORATORY MANAGER**

NOTES:

- 1) The laboratory does not take responsibility for the sample delivered after office hours.
- 2) The results pertain to the samples supplied to the laboratory.



GEOTECHNICAL SERVICES

Civil & Geotechnical Engineers
Testing Laboratory

52/3, Darul Aman Society, Haider Ali Road, Karachi.

Ph : (021) 34532851 - 34535607

E-mail : info@geotechnicalservices.com.pk

Web : www.geotechnicalservices.com.pk

Saif Ahmed Saeed
B.E. (Civil) M.Engg. AIT Bangkok

Maria Arshad
B.E. (Civil) M.S. (Geotech), NED

Hasan Ahmed Saeed
B.E. (Civil) M.Sc., (Geotech), UK

CLIENT : AQUAFIN

DATE: Nov 26, 2021.
L.R. No.: 674/21

COMPRESSIVE STRENGTH OF GROUT CUBES (2 x 2 x 2)

S. NO.	MARKING	CASTING DATE	TESTING DATE	AGE (Days)	COMPRESSIVE STRENGTH (N/mm ²)
1.	ASCORET-1/6 (w/c Ratio 0.21)	29.10.21.	26.11.21.	28	38.76
2.	"	"	"	"	36.82
3.	"	"	"	"	40.70

For GEOTECHNICAL SERVICES

MUHAMMAD AMEEN
LABORATORY MANAGER

NOTES:

- 1) The laboratory does not take responsibility for the sample delivered after office hours.
- 2) The results pertain to the samples supplied to the laboratory.