



GEOTECHNICAL SERVICES

Civil & Geotechnical Engineers
Testing Laboratory

52/3, Darul Aman Society, Haider Ali Road, Karachi.

Ph : (021) 34532851 - 34535607

E-mail : info@geotechnicalservices.com.pk

Web : www.geotechnicalservices.com.pk

Saif Ahmed Saeed
B.E. (Civil) M.Engg. AIT Bangkok

Maria Arshad
B.E. (Civil) M.S. (Geotech), NED

Hasan Ahmed Saeed
B.E. (Civil) M.Sc., (Geotech), UK

CLIENT : AQUAFIN

DATE: Feb 19, 2022.

L.R. No.: 116/22

COMPRESSIVE STRENGTH OF GROUT CUBES (2 x 2 x 2)

S. NO.	MARKING	CASTING DATE	TESTING DATE	A G E (Days)	COMPRESSIVE STRENGTH (N/mm ²)
1.	ASCORET-IM (w/c Ratio 0.17)	18.02.22.	19.02.22.	01	15.50
2.	"	"	"	"	13.56
3.	"	"	"	"	15.50

For GEOTECHNICAL SERVICES

MUHAMMAD AMEEN
LABORATORY MANAGER



GEOTECHNICAL SERVICES

Civil & Geotechnical Engineers
Testing Laboratory

52/3, Darul Aman Society, Haider Ali Road, Karachi.

Ph : (021) 34532851 - 34535607

E-mail : info@geotechnicalservices.com.pk

Web : www.geotechnicalservices.com.pk

Saif Ahmed Saeed
B.E. (Civil) M.Engg AIT Bangkok

Maria Arshad
B.E. (Civil) M.S. (Geotech), NED

Hasan Ahmed Saeed
B.E. (Civil) M.Sc. (Geotech), UK

CLIENT : AQUAFIN

DATE: Feb 21, 2022.

L.R. No.: 116/22

COMPRESSIVE STRENGTH OF GROUT CUBES (2 x 2 x 2)

S. NO.	MARKING	CASTING DATE	TESTING DATE	A G E (Days)	COMPRESSIVE STRENGTH (N/mm ²)
1.	ASCORET-IM (w/c Ratio 0.17)	18.02.22.	21.02.22.	03	23.25
2.	“	“	“	“	19.38
3.	“	“	“	“	21.32

For GEOTECHNICAL SERVICES

MUHAMMAD AMEEN
LABORATORY MANAGER



GEOTECHNICAL SERVICES

Civil & Geotechnical Engineers
Testing Laboratory

52/3, Darul Aman Society, Haider Ali Road, Karachi.
Ph : (021) 34532851 - 34535607
E-mail : info@geotechnicalservices.com.pk
Web : www.geotechnicalservices.com.pk

Saif Ahmed Saeed
B.E. (Civil) M.Engg. AIT Bangkok

Maria Arshad
B.E. (Civil) M.S. (Geotech), NED

Hasan Ahmed Saeed
B.E. (Civil) M.Sc., (Geotech), UK

CLIENT : AQUAFIN

DATE: Feb 25, 2022.
L.R. No.: 116/22

COMPRESSIVE STRENGTH OF GROUT CUBES (2 x 2 x 2)

S. NO.	MARKING	CASTING DATE	TESTING DATE	A G E (Days)	COMPRESSIVE STRENGTH (N/mm ²)
1.	ASCORET-IM (w/c Ratio 0.17)	18.02.22.	25.02.22.	07	25.19
2.	"	"	"	"	27.13
3.	"	"	"	"	25.19

For GEOTECHNICAL SERVICES

MUHAMMAD AMEEN
LABORATORY MANAGER



GEOTECHNICAL SERVICES

Civil & Geotechnical Engineers
Testing Laboratory

52/3, Darul Aman Society, Haider Ali Road, Karachi.

Ph : (021) 34532851 - 34535607

E-mail : info@geotechnicalservices.com.pk

Web : www.geotechnicalservices.com.pk

Saif Ahmed Saeed
B.E. (Civil), M.Engg. AIT Bangkok

Hasan Ahmed Saeed
B.E. (Civil), M.Sc. Birmingham, UK
Geotechnical Engineer

Maria Khan
B.E. (Urban), NED
Design Engineer

Kainat Qadeer
B.E. (Civil), NED
Design Engineer

CLIENT : AQUAFIN

DATE: March 18, 2022.

L.R. No.: 116/22

COMPRESSIVE STRENGTH OF GROUT CUBES (2 x 2 x 2)

S. NO.	MARKING	CASTING DATE	TESTING DATE	AGE (Days)	COMPRESSIVE STRENGTH (N/mm ²)
1.	ASCORET-IM (w/c Ratio 0.17)	18.02.22.	18.03.22.	28	38.76
2.	"	"	"	"	34.88
3.	"	"	"	"	36.82

For GEOTECHNICAL SERVICES

MUHAMMAD AMEEN
LABORATORY MANAGER

NOTES:

- 1) The laboratory does not take responsibility for the sample delivered after office hours.
- 2) The results pertain to the samples supplied to the laboratory.