



# GEOTECHNICAL SERVICES

Civil & Geotechnical Engineers  
Testing Laboratory

52/3, Darul Aman Society, Haider Ali Road, Karachi.

Ph : (021) 34532851 - 34535607

E-mail : info@geotechnicalservices.com.pk

Web : www.geotechnicalservices.com.pk

Saif Ahmed Saeed  
B.E. (Civil) M.Engg. AIT Bangkok

Maria Arshad  
B.E. (Civil) M.S. (Geotech), NED

Hasan Ahmed Saeed  
B.E. (Civil) M.Sc., (Geotech), UK

CLIENT : AQUAFIN

DATE: Oct 30, 2021.

L.R. No.: 674/21

## COMPRESSIVE STRENGTH OF GROUT CUBES (2 x 2 x 2)

S. NO.	MARKING	CASTING DATE	TESTING DATE	AGE (Days)	COMPRESSIVE STRENGTH (N/mm <sup>2</sup> )
1.	INDUGROUT-GP (w/c Ratio 0.15)	29.10.21.	30.10.21.	01	23.26
2.	"	"	"	"	25.19
3.	"	"	"	"	23.26

For GEOTECHNICAL SERVICES

MUHAMMAD AMEEN  
LABORATORY MANAGER

NOTES:

- 1) The laboratory does not take responsibility for the sample delivered after office hours.
- 2) The results pertain to the samples supplied to the laboratory.



# GEOTECHNICAL SERVICES

Civil & Geotechnical Engineers  
Testing Laboratory

52/3, Darul Aman Society, Haider Ali Road, Karachi.

Ph : (021) 34532851 - 34535607

E-mail : info@geotechnicalservices.com.pk

Web : www.geotechnicalservices.com.pk

Saif Ahmed Saeed  
B.E. (Civil) M.Engg. AIT Bangkok

Maria Arshad  
B.E. (Civil) M.S. (Geotech), NED

Hasan Ahmed Saeed  
B.E. (Civil) M.Sc., (Geotech), UK

CLIENT : AQUAFIN

DATE: Nov 05, 2021.

L.R. No.: 674/21

## COMPRESSIVE STRENGTH OF GROUT CUBES (2 x 2 x 2)

S. NO.	MARKING	CASTING DATE	TESTING DATE	A G E (Days)	COMPRESSIVE STRENGTH (N/mm <sup>2</sup> )
1.	INDUGROUT-GP (w/c Ratio 0.15)	29.10.21.	05.11.21.	07	40.70
2.	"	"	"	"	44.58
3.	"	"	"	"	42.63

For GEOTECHNICAL SERVICES

MUHAMMAD AMEEN  
LABORATORY MANAGER

NOTES:

- 1) The laboratory does not take responsibility for the sample delivered after office hours.
- 2) The results pertain to the samples supplied to the laboratory.



**GEOTECHNICAL SERVICES**

Civil & Geotechnical Engineers  
Testing Laboratory

52/3, Darul Aman Society, Haider Ali Road, Karachi.

Ph : (021) 34532851 - 34535607

E-mail : info@geotechnicalservices.com.pk

Web : www.geotechnicalservices.com.pk

**Saif Ahmed Saeed**  
B.E. (Civil) M.Engg. AIT Bangkok

**Maria Arshad**  
B.E. (Civil) M.S. (Geotech), NED

**Hasan Ahmed Saeed**  
B.E. (Civil) M.Sc., (Geotech), UK

**CLIENT : AQUAFIN**

**DATE: Nov 26, 2021.**

**L.R. No.: 674/21**

**COMPRESSIVE STRENGTH OF GROUT CUBES (2 x 2 x 2)**

S. NO.	MARKING	CASTING DATE	TESTING DATE	AGE (Days)	COMPRESSIVE STRENGTH (N/mm <sup>2</sup> )
1.	INDUGROUT-GP (w/c Ratio 0.15)	29.10.21.	26.11.21.	28	48.46
2.	"	"	"	"	50.39
3.	"	"	"	"	48.46

**For GEOTECHNICAL SERVICES**

**MUHAMMAD AMEEN**  
**LABORATORY MANAGER**

**NOTES:**

- 1) The laboratory does not take responsibility for the sample delivered after office hours.
- 2) The results pertain to the samples supplied to the laboratory.