



# GEOTECHNICAL SERVICES

Civil & Geotechnical Engineers  
Testing Laboratory

52/3, Darul Aman Society, Haider Ali Road, Karachi.

Ph : (021) 34532851 - 34535607

E-mail : info@geotechnicalservices.com.pk

Web : www.geotechnicalservices.com.pk

Saif Ahmed Saeed  
B.E. (Civil) M.Engg. AIT Bangkok

Maria Arshad  
B.E. (Civil) M.S. (Geotech), NED

Hasan Ahmed Saeed  
B.E. (Civil) M.Sc., (Geotech), UK

CLIENT : AQUAFIN

DATE: Feb 23, 2022.

L.R. No.: 116/22

## COMPRESSIVE STRENGTH OF GROUT CUBES (2 x 2 x 2)

S. NO.	MARKING	CASTING DATE	TESTING DATE	AGE (Days)	COMPRESSIVE STRENGTH (N/mm <sup>2</sup> )
1.	INDUGROUT-MC (w/c Ratio 0.15)	22.02.22.	23.02.22.	01	19.38
2.	"	"	"	"	17.44
3.	"	"	"	"	17.44

For GEOTECHNICAL SERVICES

MUHAMMAD AMEEN  
LABORATORY MANAGER



**GEOTECHNICAL SERVICES**

Civil & Geotechnical Engineers  
Testing Laboratory

52/3, Darul Aman Society, Haider Ali Road, Karachi.

Ph : (021) 34532851 - 34535607

E-mail : info@geotechnicalservices.com.pk

Web : www.geotechnicalservices.com.pk

**Saif Ahmed Saeed**  
B.E. (Civil) M.Engg. AIT Bangkok

**Maria Arshad**  
B.E. (Civil) M.S. (Geotech), NED

**Hasan Ahmed Saeed**  
B.E. (Civil) M.Sc., (Geotech), UK

**CLIENT : AQUAFIN**

**DATE: Feb 25, 2022.**

**L.R. No.: 116/22**

**COMPRESSIVE STRENGTH OF GROUT CUBES (2 x 2 x 2)**

S. NO.	MARKING	CASTING DATE	TESTING DATE	A G E (Days)	COMPRESSIVE STRENGTH (N/mm <sup>2</sup> )
1.	INDUGROUT-MC (w/c Ratio 0.15)	22.02.22.	25.02.22.	03	42.63
2.	“	“	“	“	44.57
3.	“	“	“	“	42.63

**For GEOTECHNICAL SERVICES**

**MUHAMMAD AMEEN  
LABORATORY MANAGER**



# GEOTECHNICAL SERVICES

Civil & Geotechnical Engineers  
Testing Laboratory

52/3, Darul Aman Society, Haider Ali Road, Karachi.

Ph : (021) 34532851 - 34535607

E-mail : info@geotechnicalservices.com.pk

Web : www.geotechnicalservices.com.pk

**Saif Ahmed Saeed**  
B.E. (Civil), M.Engg. AIT Bangkok

**Hasan Ahmed Saeed**  
B.E. (Civil), M.Sc. Birmingham, UK  
Geotechnical Engineer

**Maria Khan**  
B.E. (Urban), NED  
Design Engineer

**Kainat Qadeer**  
B.E. (Civil), NED  
Design Engineer

CLIENT : AQUAFIN

DATE: March 01, 2022.

L.R. No.: 116/22

## COMPRESSIVE STRENGTH OF GROUT CUBES (2 x 2 x 2)

S. NO.	MARKING	CASTING DATE	TESTING DATE	A G E (Days)	COMPRESSIVE STRENGTH (N/mm <sup>2</sup> )
1.	INDUGROUT-MC (w/c Ratio 0.15)	22.02.22.	01.03.22.	07	54.27
2.	"	"	"	"	52.33
3.	"	"	"	"	56.21

For GEOTECHNICAL SERVICES

MUHAMMAD AMEEN  
LABORATORY MANAGER

### NOTES:

- 1) The laboratory does not take responsibility for the sample delivered after office hours.
- 2) The results pertain to the samples supplied to the laboratory.



**GEOTECHNICAL SERVICES**

Civil & Geotechnical Engineers  
Testing Laboratory  
523. Darul Aman Society, Haider Ali Road, Karachi.  
Ph : (021) 34532851 - 34535607  
E-mail : info@geotechnicalservices.com.pk  
Web : www.geotechnicalservices.com.pk

**Saif Ahmed Saeed**  
B.E. (Civil), M.Engg. AIT Bangkok

**Hasan Ahmed Saeed**  
B.E. (Civil), M.Sc. Birmingham, UK  
Geotechnical Engineer

**Maria Khan**  
B.E. (Urban), NED  
Design Engineer

**Kainat Qadeer**  
B.E. (Civil), NED  
Design Engineer

**CLIENT : AQUAFIN**

**DATE: March 22, 2022.**  
**L.R. No.: 116/22**

**COMPRESSIVE STRENGTH OF GROUT CUBES (2 x 2 x 2)**

S. NO.	MARKING	CASTING DATE	TESTING DATE	AGE (Days)	COMPRESSIVE STRENGTH (N/mm <sup>2</sup> )
1.	INDUGROUT-MC (w/c Ratio 0.15)	22.02.22.	22.03.22.	28	69.77
2.	"	"	"	"	73.65
3.	"	"	"	"	73.65

**For GEOTECHNICAL SERVICES**

**MUHAMMAD AMEEN**  
**LABORATORY MANAGER**

**NOTES:**

- 1) The laboratory does not take responsibility for the sample delivered after office hours.
- 2) The results pertain to the samples supplied to the laboratory.